



इटर-इण्डिया, प्लाज्मा अनुसंधान संस्थान

ITER-India, Institute for Plasma Research

ब्लॉक ए, संगथ स्काइज़, भाट – मोटेरा रोड, कोटेश्वर, अहमदाबाद – 380 005, गुजरात, भारत

www.iter-india.org

Block A, Sangath SKYZ, Bhat – Motera Road, Koteswar, Ahmedabad - 380 005, Gujarat, India

Phone: +91-79-23269656
Fax: +91-79-23269501/9591

Email: rakhi.dharamdasani@iter-india.org /
purchase@iter-india.org

AMENDMENT-I

Amendment Issue Date: 10-March-2021

Reference: Enquiry No. I-IEN20065 dated 27-January-2021

The Enquiry No. referred to above is amended as under:

With reference to the above, this is an amendment issued to the Enquiry No. I-IEN20065 dated 27-January-2021 for “33kV 630A High Voltage Offload changeover switch panel”. This amendment forms an integral part of the original enquiry documents of the above referred enquiry.

In Place Of
<p>Annexure-I Technical Specifications</p> <p>Clause No. 5. Technical Specifications :</p> <p>Sr. No. 20 : Safety Features and interlocks:</p> <p>3. Earth Switch 1</p> <p>“Earth switch 1 cannot be closed , until incoming breaker is ON”</p>
<p>Annexure-I Technical Specifications</p> <p>Clause No. 6. Acceptance Test Procedure :</p> <p>FAT</p> <p>Section E Interlock test for High voltage offload change over switch</p> <p>2. Earth Switch 1</p> <p>“Earth switch 1 cannot be closed , until incoming breaker is ON”</p>
<p>Annexure-I Technical Specifications</p> <p>Clause No. 6. Acceptance Test Procedure :</p> <p>SAT</p> <p>Section C Interlock test for High voltage offload change over switch</p> <p>2. Earth Switch 1</p> <p>“Earth switch 1 cannot be closed , until incoming breaker is ON”</p>



इटर-इण्डिया, प्लाज्मा अनुसंधान संस्थान

ITER-India, Institute for Plasma Research

ब्लॉक ए, संगथ स्काइज़, भाट – मोटेरा रोड, कोटेश्वर, अहमदाबाद – 380 005, गुजरात, भारत

www.iter-india.org

Block A, Sangath SKYZ, Bhat – Motera Road, Koteshwar, Ahmedabad - 380 005, Gujarat, India

Phone: +91-79-23269656

Email: rakhi.dharamdasani@iter-india.org /

Fax: +91-79-23269501/9591

purchase@iter-india.org

Annexure-I Technical Specifications

Annexure C. Guaranteed Technical particular to be filled by vendor:

Sr. No. 20 : Safety Features and interlocks:

2. Earth Switch 1

"Earth switch 1 cannot be closed , until incoming breaker is ON"

Read As

Annexure-I Technical Specifications

Clause No. 5. Technical Specifications :

Sr. No. 20 : Safety Features and interlocks:

3. Earth Switch 1

"Earth switch 1 cannot be closed , if incoming breaker is ON".

Annexure-I Technical Specifications

Clause No. 6. Acceptance Test Procedure :

FAT

Section E Interlock test for High voltage offload change over switch

2. Earth Switch 1

"Earth switch 1 cannot be closed , if incoming breaker is ON".

Annexure-I Technical Specifications

Clause No. 6. Acceptance Test Procedure :

SAT

Section C Interlock test for High voltage offload change over switch

2. Earth Switch 1

"Earth switch 1 cannot be closed , if incoming breaker is ON".



इटर-इण्डिया, प्लाज्मा अनुसंधान संस्थान

ITER-India, Institute for Plasma Research

ब्लॉक ए, संगथ स्काइज़, भाट – मोटेरा रोड, कोटेश्वर, अहमदाबाद – 380 005, गुजरात, भारत

www.iter-india.org

Block A, Sangath SKYZ, Bhat – Motera Road, Koteswar, Ahmedabad - 380 005, Gujarat, India

Phone: +91-79-23269656

Email: rakhi.dharamdasani@iter-india.org /

Fax: +91-79-23269501/9591

purchase@iter-india.org

Annexure-I Technical Specifications

Annexure C. Guaranteed Technical particular to be filled by vendor:

Sr. No. 20 : Safety Features and interlocks:

2. Earth Switch 1

"Earth switch 1 cannot be closed , if incoming breaker is ON".

Except this amendment, all other technical details, Scope of supply/work and terms and conditions of our above referred Enquiry shall remain unchanged.

Rakhi Dharamdasani
Sr. Officer (Purchase & Stores)
ITER-India (IPR)