

Technical Specifications of Laying and Installation of Copper Foil(s).

1	Scope of Work								
	a) Laying and Installation Copper Foil(s) as per specifications								
2	Laying, Installation and joining of Copper Foils (Copper Foil Network- CFN)								
	<table> <tr> <td>Laying length for 300mm x 1mm thick copper foil.</td><td> <p>Approx. 140mts (This length may increase or decrease as per physical situation at the site.)</p> <p>Note: The laying length mentioned in price bid is for calculation of budgetary estimate/bid. Actual billing/payment will be made based on the actual measurement and rate submitted by the bidder at the time of bid submission.</p> <p>Per meter rate of laying & installation (including joints) shall be mentioned in the price bid format.</p> </td></tr> <tr> <td>Joints of Copper foils (by bolting/screwing)</td><td> <p>Joints of the copper foils shall be included in the laying length as mentioned above.</p> <p>Copper foils joints shall have overlapping of 300 x 300mm. To improve contact, copper braid(s) shall be sandwiched between two copper foils for complete 300 x 300mm overlapping area. Copper braid shall be under the scope of installation agency.</p> <p>Joints are likely to increase/decrease as per actual site condition. (For rough estimation of joints tentative layout Annexure B may be referred)</p> <p>Note: No separate rates of joints. Joints price/rate shall be included in the per meter rate of price bid format.</p> </td></tr> <tr> <td>Installation</td><td> <p>Installation of the 300mm x 1mm copper foil may be on floor/wall/mezzanine or any surface as suggested by the purchaser. Installation length will be same as laying length. All hardware (screws, washers etc.) shall be under the scope of installation agency. On floor installation shall be done with screws on the floor.</p> <p>Some open ends of the copper foils, may require to drills 3 no.s of 6-8mm dia. holes</p> </td></tr> <tr> <td>Tentative Layout</td><td> <p>As per Annexure B</p> <p>Note: The layout shown above is tentative and not final. Actual installation may vary as per site condition.</p> </td></tr> </table>	Laying length for 300mm x 1mm thick copper foil.	<p>Approx. 140mts (This length may increase or decrease as per physical situation at the site.)</p> <p>Note: The laying length mentioned in price bid is for calculation of budgetary estimate/bid. Actual billing/payment will be made based on the actual measurement and rate submitted by the bidder at the time of bid submission.</p> <p>Per meter rate of laying & installation (including joints) shall be mentioned in the price bid format.</p>	Joints of Copper foils (by bolting/screwing)	<p>Joints of the copper foils shall be included in the laying length as mentioned above.</p> <p>Copper foils joints shall have overlapping of 300 x 300mm. To improve contact, copper braid(s) shall be sandwiched between two copper foils for complete 300 x 300mm overlapping area. Copper braid shall be under the scope of installation agency.</p> <p>Joints are likely to increase/decrease as per actual site condition. (For rough estimation of joints tentative layout Annexure B may be referred)</p> <p>Note: No separate rates of joints. Joints price/rate shall be included in the per meter rate of price bid format.</p>	Installation	<p>Installation of the 300mm x 1mm copper foil may be on floor/wall/mezzanine or any surface as suggested by the purchaser. Installation length will be same as laying length. All hardware (screws, washers etc.) shall be under the scope of installation agency. On floor installation shall be done with screws on the floor.</p> <p>Some open ends of the copper foils, may require to drills 3 no.s of 6-8mm dia. holes</p>	Tentative Layout	<p>As per Annexure B</p> <p>Note: The layout shown above is tentative and not final. Actual installation may vary as per site condition.</p>
Laying length for 300mm x 1mm thick copper foil.	<p>Approx. 140mts (This length may increase or decrease as per physical situation at the site.)</p> <p>Note: The laying length mentioned in price bid is for calculation of budgetary estimate/bid. Actual billing/payment will be made based on the actual measurement and rate submitted by the bidder at the time of bid submission.</p> <p>Per meter rate of laying & installation (including joints) shall be mentioned in the price bid format.</p>								
Joints of Copper foils (by bolting/screwing)	<p>Joints of the copper foils shall be included in the laying length as mentioned above.</p> <p>Copper foils joints shall have overlapping of 300 x 300mm. To improve contact, copper braid(s) shall be sandwiched between two copper foils for complete 300 x 300mm overlapping area. Copper braid shall be under the scope of installation agency.</p> <p>Joints are likely to increase/decrease as per actual site condition. (For rough estimation of joints tentative layout Annexure B may be referred)</p> <p>Note: No separate rates of joints. Joints price/rate shall be included in the per meter rate of price bid format.</p>								
Installation	<p>Installation of the 300mm x 1mm copper foil may be on floor/wall/mezzanine or any surface as suggested by the purchaser. Installation length will be same as laying length. All hardware (screws, washers etc.) shall be under the scope of installation agency. On floor installation shall be done with screws on the floor.</p> <p>Some open ends of the copper foils, may require to drills 3 no.s of 6-8mm dia. holes</p>								
Tentative Layout	<p>As per Annexure B</p> <p>Note: The layout shown above is tentative and not final. Actual installation may vary as per site condition.</p>								

3	CFN and connection
	<p>Following material(s)/item(s) will be used for installation, laying, connections etc.</p> <ul style="list-style-type: none"> 300mm x 1mm Copper Foil (under scope of Purchaser/ITER-India) <p>However, the above material shall not be taken out of the ITER-India/IPR premises. The above items may be used as and when required for installation, laying, connections etc. only.</p>
4	Measurement Philosophy
	Copper foil(s) measurement for billing will be done from centre of the width. For joints, Tee(s)etc. same philosophy may be adopted.
5	General Term & Conditions
	<p>a) Bidder shall submit the <u>duly signed and stamped on each page</u> of Annexure-C Technical Compliance Sheet at the time of submission of bid.</p> <p>b) Any typo error/spelling mistake in drawing(s)/specification(s) shall be communicated to ITER-India, if any. Any confusion will not be entertained/considered at later stage.</p> <p>c) Any overlooking by purchaser does not waives the responsibility of supplier to meet the specifications.</p>
6	Installation Address
	<p>DNB Lab, ITER-India building, Institute for Plasma Research, Near Amul Dairy, Airport Road, Bhat, Ahmedabad-382428</p>
7	Payment Terms
	<p>a) Payment will be made within 30 days through NEFT/RTGS from the date of final acceptance on submission of error free invoice along with all supporting documents (Joint Measurement Sheet).</p> <p>b) Payment to be made against actual quantity/work done after actual measurement.</p>
8	Price Basis
	Price basis in BoQ shall be exclusive of taxes, duties & any other charges & on free door delivery basis. Price shall be quoted for complete scope of work & technical specifications as mentioned in this documents.

Page 3 of 6

Annexure C Technical Compliance & Price Compliance Sheet

Description		Bidder Compliance (Yes/No), remarks if any
Details from Sr.1 to Sr.8 are completely understood. Do you agree and abide the same? (Yes/No)		
The price/rate submitted in the Price Bid Format is final and has been submitted after clear understanding of technical specifications. Any other Price breakup attached/submitted other than on the authorised Portal will not be considered as valid for evaluation. Do you agree and abide? Yes/No.		
Everything of the technical specifications is included in the submitted price bid of the authorised portal. (Yes/No)?		
I understand that technical evaluation will be done based on this Technical Compliance sheet. Other information submitted may not be considered. (Yes/No)?		
Laying length for 300mm x 1mm thick copper foil.	Approx. 140mts (This length may increase or decrease as per physical situation at the site.) <i>Note: The laying length mentioned in price bid is for calculation of budgetary estimate/bid. Actual billing/payment will be made based on the actual measurement and rate submitted by the bidder at the time of bid submission.</i> <i>Per meter rate of laying & installation (including joints) shall be mentioned in the price bid format.</i> Do you comply? Yes/No	
Joints of Copper foils (by bolting/screwing)	Joints of the copper foils shall be included in the laying length as mentioned above. Copper foils joints shall have overlapping of 300 x 300mm. To improve contact, copper braid(s) shall be sandwiched between two copper foils for complete 300 x 300mm overlapping area. Copper braid shall be under the scope of installation agency. Joints are likely to increase/decrease as per actual site condition. (For rough estimation of joints tentative layout Annexure B may be referred) <i>Note: No separate rates of joints. Joints price/rate shall be included in the per meter rate of price bid format.</i> Do you comply? Yes/No	
Installation	Installation of the 300mm x 1mm copper foil may be on floor/wall/mezzanine or any surface as suggested by the purchaser. Installation length will be same as laying length. All hardware (screws, washers etc.) shall be under the scope of installation agency. On floor installation shall be done with screws on the floor.	

	Some open ends of the copper foils, may require to drills 3 no.s of 6-8mm dia. holes Do you comply? Yes/No	
Tentative Layout	The layout shown in Annexure B is tentative and not final. Actual installation may vary as per site condition. Do you comply? Yes/No	
Payment Terms	<p>a) Payment will be made within 30 days through NEFT/RTGS from the date of final acceptance on submission of error free invoice along with all supporting documents (Joint Measurement Sheet).</p> <p>b) Payment to be made against actual quantity/work done after actual measurement.</p> Do you comply? Yes/No	
Price Basis	Price basis in BoQ shall be exclusive of taxes, duties & any other charges & on free door delivery basis. Price shall be quoted for complete scope of work & technical specifications as mentioned in this documents. Do you comply? Yes/No	

Bidder Signature		
Name of the signatory & Title	Name	Title
Bidder's Official seal		
Place & Date	Place	DD-MM-YYYY

Annexure-I: Self-declaration by Bidder of a country sharing/not sharing land border with
India

[ON THE LETTER HEAD OF THE COMPANY]

Ref: 1) Our bid/offer No. dated

2) E-Tender No. I-I/ET/25012/25-26

**Restrictions on procurement from Bidders from a country or countries, or class of countries under
Rule 144(xi) of the General Financial Rules 2017.**

We have read the clause regarding restrictions on procurement from Bidder of a country which shares a land border with India and on sub-contracting to contractors from such countries, and solemnly certify that we fulfil all requirements in this regard and are eligible to be considered. We certify that:

- (a) *we are not from such a country or, if from such a country, we are registered with the Competent Authority (copy enclosed). and;*
- (b) *we shall not subcontract any work to a contractor from such countries unless such contractor is registered with the Competent Authority and solemnly certify that we are not from such a country or, if from such country, we are registered with the Competent Authority (copy enclosed). We hereby certify that we fulfil all requirements in this regard and are eligible to be considered.”*

Penalties for false or misleading declarations:

We hereby confirm that the particulars given above are factually correct and nothing is concealed and also undertake to advise any further changes to the above details. We understood that any wrong or misleading self-declaration by us would be violation of Code of integrity and would attract penalties as mentioned in this tender document, including debarment.

Signature

Bidder's

stamp

Name:

Position:

Address:

Tel:

Fax:

Email ID