

Guideline

EDH Part 3: Codes & Standards

Part 3 of the revised ITER Cadarache relevant Electrical Design Handbook

Approval Process			
	Name	Action	Affiliation
Author	Goff J. (Account Closed)	15 Sep 2009:signed	
Co-Authors	Hourtoule J.	15 Sep 2009:signed	IO/DG/COO/PED/EED/EPD
Reviewers	Benfatto I.	15 Sep 2009:recommended	IO/DG/COO/PED/EED
	Joonekindt D. (Account Closed)	16 Sep 2009:recommended	
	Journeaux J.- Y.	15 Sep 2009:recommended	IO/DG/COO/TED/MAG/SSA
	Kim Y.- H.	15 Sep 2009:recommended	ITER Organization (IO)
	Sands D.	15 Sep 2009:recommended	IO/DG/RCO
	Tada E.		
Approver	Holtkamp N.	20 Sep 2009:approved	SLAC - National Accelerator Laboratory (US)
Document Security: Internal Use RO: Goff Jeremy (Account Closed)			
Read Access	GG: MAC Members and Experts, GG: STAC Members & Experts, AD: ITER, AD: External Collaborators, AD: IO_Director-General, AD: EMAB, AD: Auditors, AD: ITER Management Assessor, project administrator, RO, LG: [CCS] CCS-All for Ext AM, LG: [CCS] CCS-Section Leaders, LG: [CCS] JACOBS, LG: [CCS] CCS-Doc Co...		

<i>Change Log</i>			
EDH Part 3: Codes & Standards (2E8DLM)			
<i>Version</i>	<i>Latest Status</i>	<i>Issue Date</i>	<i>Description of Change</i>
v1.0	In Work	16 May 2008	Part 3 of the revised ITER Cadarache relevant Electrical Design Handbook
v1.1	Signed	02 Sep 2008	Part 3 of the revised ITER Cadarache relevant Electrical Design Handbook
v1.2	Signed	23 Jul 2009	New IO Document Format and review by main author
v1.3	Approved	15 Sep 2009	All previous review comments addressed



Electrical Design Handbook

Part 3: Codes and Standards

Abstract

This part of the EDH lists all codes and standards to which reference may be made when specifying an electrical component, device or system for use by ITER Organization.

	IDM Number: IDM_D_2E8DLM v1.3	Date: 15/09/2009 15:15:00
	Name	Affiliation
Authors	Jerry Goff, Joël Hourtoule	Central Engineering and Plant Support
Reviewers	Ivone Benfatto, Didier Joonekindt, Jean-Yves Journeaux, Yong-Hwan Kim, David Sands, Eisuke Tada	ITER Organization
Approver	Norbert Holtkamp	ITER Organization

Major Changes

Version	Date	Location	What
1.0	May 10 th 2008	IO	First Release
1.1	May 26 th 2008	ALVARO CARDIEL	MV & LV cables
1.1.5	June 13 th 2008	JOEL HOURTOULE	Details corrected
1.2	23 rd July 2009		New IO Document Format and review by main author
1.3	15 th September 2009		Incorporation of 1 st review comments

Contents

1	<i>Introduction.....</i>	<i>3</i>
2	<i>General Binding Rules and Guidelines.....</i>	<i>3</i>
3	<i>International Standards Related to Nuclear Safety.....</i>	<i>4</i>
4	<i>Applicable Standards for Electrical Distribution Networks in Nuclear Power Plants.....</i>	<i>9</i>
4.1	<i>Applicable Standards by Voltage Level.....</i>	<i>10</i>
4.1.1	HIGH VOLTAGE	10
4.1.2	MEDIUM VOLTAGE	13
4.1.3	LOW VOLTAGE	22

Tables

<i>Table 4.1-1</i>	<i>Standards for HV Electrical Components</i>	<i>10</i>
<i>Table 4.1-2</i>	<i>Standards for MV Electrical Components</i>	<i>13</i>
<i>Table 4.1-3</i>	<i>Standards for LV Electrical Components</i>	<i>22</i>

1 Introduction

The general adopted guidelines referring to codes and standards shall take account of the following needs:

1. To adopt wherever possible the international electrical standards issued by the International Electrotechnical Commission (IEC).
2. To facilitate the licensing process by adopting French Standards and European Directives covering the following items:
 - a. Installation and operation rules;
 - b. Design, manufacturing and testing of components affecting safety (nuclear and personnel) and fire protection.

The identification of codes and standards applicable to electrical equipment shall also take account of the European harmonisation process which started in the 1950s in support of European legislation and which has helped shape the European internal market. This harmonisation process is coordinated by CENELEC, the European Committee for Electrical Standardisation. This Committee also supports the IEC in achieving its mission and therefore promotes the harmonisation between the electrical standards adopted by the EU Member States and the international electrical standards issued by the IEC. As a consequence of this process, a large proportion of the national electrical standards of the EU Member States are harmonised with the IEC standards.

The main codes and standards, affecting nuclear safety, are also reported in the Preliminary Safety Report (Rapport Préliminaire de Sûreté) (RPrS).. This EDH may require revision following approval of the RPrS.

2 General Binding Rules and Guidelines

Electrical components, devices or systems shall be designed, constructed, tested and operated in accordance with best engineering and industry practice.

The codes and standards listed hereafter apply to the design, manufacturing, testing, installation and operation of electrical components, device or systems for use in the ITER plant:

1. Code and Standards listed in the ITER Preliminary Safety Report.
2. French Standards and Rules applicable or affecting:
 - a. Safety (nuclear and personnel safety);
 - b. Fire prevention, fire detection and/or fire suppression;
 - c. Guidelines and rules for installation of electrical components, devices or systems;
 - d. Applicable building codes.
3. European Directives.
4. Codes, Standards and Design Criteria reported in the ITER Baseline Documentation, Task Agreements, Contract Technical Specifications and Procurement Arrangement documents.
5. IEC standards.

The above list also indicates the top-down priority to be considered in case of inconsistency among the codes standards and design criteria quoted in the above listed documents.

If the approval process of a code or standard is well advanced and is expected to come into force during the manufacturing, installation or operational phase of ITER, the ITER Organization may decide to immediately apply the draft version of the new code or standard.

The following chapters and paragraphs of this document have been produced to assist the staff of the ITER Organization and the Domestic Agencies in the identification of the codes and standards applicable to the design, manufacturing, testing, installation and operation of electrical components, devices or systems for use in the ITER plant. However, the following chapters are for information only, therefore designers, manufactures and operators of electrical components, devices and systems shall ensure the implementation of the general binding rules and guidelines reported in the above paragraphs of this Chapter 2.

3 International Standards Related to Nuclear Safety

<u>Standard</u>	<u>Description</u>
IEC 60439-1	Low-Voltage switchgear and control gear assemblies. Part 1: Type tested and partially type-tested assemblies
IEC 60034-1 / NF EN 60034-1	Rotating electrical machines-Part 1: Rating and Performances
IEC 60038	IEC standard voltages
IEC 60050-161	International Electrotechnical Vocabulary. Chapter 161: Electromagnetic compatibility
IEC 60050-461	International Electrotechnical Vocabulary. Chapter 461: Electric cables
IEC 60059	IEC standard current ratings
IEC 60060-1,...,3	High Voltage test techniques
IEC 60068	Environmental testing
IEC 60068-1	Environmental testing – Part 1 General and Guidance
IEC 60068-2-14	Environmental testing – Part 2: Tests –Test N: Change of temperature
IEC 60068-2-2	Basic environmental testing procedure f-Part 2: Tests – Tests B: Dry Heat
IEC 60068-2-57	Environmental testing – Part 2: Tests –Test Fc: Vibration Time history method
IEC 60068-2-59	Environmental testing – Part 2-57: Tests –Test Ff: Sine-Beat method
IEC 60068-2-6	Environmental testing – Part 2: Tests –Test Fc: Vibration (sinusoidal)
IEC 60068-3-3	Environmental testing. Part 3 : Guidance –Seismic test method for equipment
IEC 60071-1,2	Insulation co-ordination
IEC 60076-11	Power transformers – Part 11 : Dry-type transformers
IEC 60085	Electrical insulation - Thermal evaluation and designation
IEC 60146-2	Semiconductor converters – Part 2 : Self commutated semiconductor converters including direct dc converters
IEC 60216-1	Electrical insulating materials - Properties of thermal endurance - Part 1: Ageing procedures and evaluation of test results
IEC 60216-2	Electrical insulating materials - Thermal endurance properties - Part 2: Determination of thermal endurance properties of electrical insulating materials - Choice of test criteria
IEC 60231A	General principles of nuclear reactor instrumentation
IEC 60297-1	Dimensions of mechanical structures of the 482.6 mm (19 in) series. Part 1: Panels and racks

<u>Standard</u>	<u>Description</u>
IEC 60297-2	Dimensions of mechanical structures of the 482.6 mm (19 in) series. Part 2: Cabinets and pitches of rack structures
IEC 60297-3	Mechanical structures for electronic equipment - Dimensions of mechanical structures of the 482,6 mm (19 in) series
IEC 60300	Dependability management
IEC 60332-1-1	Tests on electric and optical fibre cables under fire conditions - Part 1-1: Test for vertical flame propagation for a single insulated wire or cable – Apparatus
IEC 60332-1-2	Tests on electric and optical fibre cables under fire conditions - Part 1-2: Test for vertical flame propagation for a single insulated wire or cable - Procedure for 1 kW pre-mixed flame
IEC 60332-1-3	Tests on electric and optical fibre cables under fire conditions - Part 1-3: Test for vertical flame propagation for a single insulated wire or cable - Procedure for determination of flaming droplets/particles
IEC 60332-2-1	Tests on electric and optical fibre cables under fire conditions - Part 2-1: Test for vertical flame propagation for a single small insulated wire or cable - Apparatus
IEC 60332-2-2	Tests on electric and optical fibre cables under fire conditions - Part 2-2: Test for vertical flame propagation for a single small insulated wire or cable - Procedure for diffusion flame
IEC 60332-3-10	Tests on electric cables under fire conditions - Part 3-10: Test for vertical flame spread of vertically-mounted bunched wires or cables - Apparatus
IEC 60352-1	Solderless connections - Part 1: Wrapped connections - General requirements, test methods and practical guidance
IEC 60352-2	Solderless connections - Part 2: Crimped connections - General requirements, test methods and practical guidance
IEC 60359	Electrical and electronic measurement equipment - Expression of performance
IEC 60364 NF C 15-100	Low voltage Electrical Installations Rules
IEC 60364-4-41	Low-voltage electrical installations - Part 4-41: Protection for safety - Protection against electric shock
IEC 60446	Basic and safety principles for man-machine interface, marking and identification – Identification of conductors by colours or alphanumerics
IEC 60470	High-voltage alternating current contactors and contactor-based motor-starters
IEC 60479-1	Effects of current on human beings and livestock – Part 1: General aspects
IEC 60529	Degrees of protection provided by enclosures (IP code)
IEC 60654-2	Operating conditions of measurement, control equipment in industrial processes
IEC 60671	Nuclear power plants - Instrumentation and control systems important to safety - Surveillance testing
IEC 60695-11-20	Fire hazard testing - Part 11-20: Test flames - 500 W flame test methods
IEC 60706	Maintainability of equipment
IEC 60721	Classification of environmental classes and severity levels
IEC 60725	Reference impedance for LV power lines
IEC 60780	Nuclear power plants - Electrical equipment of the safety system – Qualification

<u>Standard</u>	<u>Description</u>
IEC 60811-1-2	Insulating and sheathing materials of electric cables – common test methods Part 1-2: Method for general application- thermal ageing method
IEC 60880	Nuclear power plants - Instrumentation and control systems important to safety - Software aspects for computer-based systems performing category A functions
IEC 60909-0	Short-circuit currents in three-phase ac systems - Part 0: Calculation of currents
IEC 60947-2	Low voltage switchgear and control gear – Part 2: Circuit Breakers.
IEC 60947-3	Low voltage switchgear and control gear – Part 3: Switches, disconnectors, switch-disconnectors and fuse combination units.
IEC 60947-4-1	Low voltage switchgear and control gear – Part 4-1: Contactors and motors starters- Electromechanical contactors and motor starters
IEC 60964	Design for control rooms of nuclear power plants
IEC 60980	Recommended practices for seismic qualification of electrical equipment of the safety system for nuclear generating stations
IEC 61000-1	Electromagnetic compatibility. General considerations
IEC 61000-1-2	Methodology to achieve functional safety on E/E equipment
IEC 61000-2-10	Description of HEMP environment - Conducted disturbance
IEC 61000-2-11	Environment - Classification of HEMP environments
IEC 61000-2-12	Compatibility levels for low frequency conducted disturbances and signalling in public medium voltage power supply systems
IEC 61000-2-13	Environment - High-power electromagnetic (HPEM) environments - Radiated and conducted
IEC 61000-2-2	Compatibility levels in public LV power systems
IEC 61000-2-3	Description, radiated and non-network frequency conducted disturbances
IEC 61000-2-4	Compatibility levels in industrial plants
IEC 61000-2-5	Classification of the EM environments
IEC 61000-2-7	Low frequency magnetic fields in various environments
IEC 61000-2-8	Voltage dips, short interruptions
IEC 61000-2-9	Description of HEMP environment - Radiated disturbance
IEC 61000-3	Emission variations distribution networks
IEC 61000-4	Immunity tests
IEC 61000-4-7	Measurement techniques. Harmonics
IEC 61000-5	Installation and mitigation guidelines. Protection degree
IEC 6100-6-2	Generic standard Industrial environmental immunity
IEC 6100-6-4	Generic standard Industrial environmental emissions
IEC 61014	Programs for reliability growth
IEC 61024-1-1 (Replaced by 62305-1)	Protection against lightning - Part 1: General principles

<u>Standard</u>	<u>Description</u>
IEC 61024-1-2 (Replaced by 62305-3)	Protection against lightning - Part 3: Physical damage to structures and life hazard
IEC 61124	Reliability testing - Compliance tests for constant failure rate and constant failure intensity
IEC 61131-2	Programmable controllers - Part 2: Equipment requirements and tests
IEC 61160	Design review
IEC 61163	Reliability stress screening
IEC 61165	Application of Markov Techniques
IEC 61180-1	High-voltage test techniques for low voltage equipment – Part 1: Definitions, test and procedure requirements
IEC 61189	Test methods for electrical materials, interconnection structures and assemblies
IEC 61225	Safety Instrumented systems for process industry
IEC 61226	Nuclear Power Plants - Instrumentation and Control Systems Important to Safety - Classification of Instrumentation and Control Functions
IEC 61227	Nuclear power plants - Control rooms – Operator controls
IEC 61312-1 (Replaced by 62305-4)	Protection against lightning - Part 4: Electrical and electronic systems within structures
IEC 61312-4 (Replaced by 62305-4)	Protection against lightning - Part 4: Electrical and electronic systems within structures
IEC 61326	Electrical equipment for measurement control and laboratory use
IEC 61508-1,...,7	Functional safety of electrical electronic/electronic programmable safety
IEC 61513	Nuclear power plants - Instrumentation and control for systems important to safety - General requirements for systems
IEC 61662 (Replaced by 62305-2)	Protection against lightning - Part 2: Risk management
IEC 61709	Reference conditions for failure rates and stress models for conversions
IEC 61771	Nuclear power plants - Main control-room - Verification and validation of design
IEC 61772	Nuclear power plants - Main control room - Application of visual display units (VDU)
IEC 61936-1	Electrical Installations of nominal voltage above 1 kV in AC
IEC 62138	Nuclear power plants - Instrumentation and control important for safety - Software aspects for computer-based systems performing category B or C functions
IEC 62262	Degrees of protection provided by enclosures for electrical equipment against external mechanical impacts (IK codes)
IEC 62271-100	High-voltage switchgear and control gear - Part 100: High-voltage alternating-current circuit-breakers
IEC 62271-200	High-voltage switchgear and control gear - Part 200: AC metal-enclosed switchgear and control gear for rated voltages above 1 kV and up to and including 52 kV

<u>Standard</u>	<u>Description</u>
IEC 62308	Reliability assessment methods
IEC 62347	Guidance on system dependability specifications
IEC 62429	Reliability growth – Stress testing for early failures in unique complex systems
IEC/TS 61000-6-5	Electromagnetic compatibility (EMC) - Part 6-5: Generic standards - Immunity for power station and substation environments
NF C 13-200	High Voltage Electrical Installations – Requirements (V<63 kV)
NF C 15-100	Low Voltage Electrical Installations
NF C 17-100	Protection against Lightning – Protection of structures against Lightning- Installation of lightning Protective System
NF C 32-070	Classification test on cable and cords with respect of the behaviour to fire insulated cables and flexible cords for installations
NF C 93-022	Electronic components-Point-to-point Clip Terminals
NF C04-200	Marking of conductors (status change of the standard NF C 04-200 dated June 1974, ENR)
NF EN 2812-1	Paints and varnishes – determinations of resistance to liquids – Part 1: General methods
NF EN 45014	General Criteria for Supplier's Declaration of Conformity
NF EN 50110 -1,2	Operation of electrical installations
NF EN ISO 9000-3	Quality assurance and quality management standards – Part 3: Directives for the application of ISO 9001:2004 with reference to the provision, installation and maintenance of software
NF ISO 2859-0	Sample procedures for inspection by attributes. Part 0: Introduction to the ISO 2859 Attribute Sampling System.
NF ISO 3951	Sampling procedures and charts for inspection by variables
NF ISO 9001	Quality management systems – Requirements
NF M 64-001	Procedure for qualifications of electric equipment installed in containments for pressurised water reactors and subject to accident conditions.
NF T 30-900	Paints and varnishes. Paint for the nuclear industry. Behavioural test under controlled accident conditions and reparability of paint systems (PWR)
NF T 30-901	Paints and varnishes. Paint for the nuclear industry. Performance test for susceptibility to contamination and fitness to decontamination.
NF T 30-903	Paints and varnishes. Paint for the nuclear industry.- Test of the behaviour in ionising radiation (PWR)
NF X 06-021	Application of statistics – Principles of the statistical control of batches.
UTE C93-751	Electronic components – Base materials for printed circuits – Detailed specifications.
UTE C96-027	Semi-conductor devices. Rules concerning the management of product discontinuance and replacement (obsolescence of electronic components) Provisional recommendations.
UTE-C18-540	Operation of electrical installations

4 Applicable Standards for Electrical Distribution Networks in Nuclear Power Plants

A table of standards applicable to every device has been created and organised by standard category.

Standards applicable for each component list are organised as described below:

- Manufacturing Standard: Processes used by a manufacturer including communication standard, e.g. IEC 61850: Seismic Area
- Site Installation Standard: Standards to be met in order to enable the operation of the system in all situations
- Personal Safety: Standards to be met for personal safety during the construction and device installation phase. Standards for personal protection in case of fault due to the device or due to human factors
- Nuclear Safety: Standards defined for every nuclear installation. (Refer to RCC-E manual)
- Tokamak Building: A particularity of this building is the high humidity level that may occur in event of an accident. Consequently, components installed in that building must tolerate this condition
- Tokamak Complex (including buildings 11, 14 and 74): Particularities of these buildings are that no halogen is allowed; consequently any component installed in these buildings must respect this condition
- Test and Commissioning: All standards to be met during tests, including tests after installation, recurring commissioning tests during the exploitation and tests after a fault
- Devices Installed Inside or Outside: For all equipment, an analysis must be performed to determine the influence of an installation inside or outside. In accordance with SRD conditions

4.1 Applicable Standards by Voltage Level

4.1.1 HIGH VOLTAGE

Table 4.1-1 Standards for HV Electrical Components

SEEN EQUIPMENT	Manufacturing Standard	Indoor / Outdoor Facilities	Site Installation Standard	Nuclear Safety	Personal Safety	Tokamak Complex	Test
HIGH VOLTAGE							
400 kV SWITCHYARD							
CIRCUIT BREAKER							
	IEC 60071-2 IEC 60265-2 IEC 62271-1 IEC 62271-100 IEC 62271-102	IEC 60068-1	IEC 60265-2 IEC 61140 IEC 61936 IEC 62271-1 IEC 62271-100 IEC 62271-102 NFC 13000 HD 637 S1	IEC 60068-3-3	IEC 60479 IEC 61140 IEC 62271-1 IEC 62271-100 IEC 62271-102		IEC 60060 – 1 IEC 60068-1 IEC 60068-2-1 IEC 60068-2-2 IEC 60068-2-30 IEC 60068-3-3 IEC 60265-2 IEC 60815 IEC 62271-1 IEC 62271-100 IEC 62271-102 IEC 62271-300
DISCONNECTOR							

SSEN EQUIPMENT	Manufacturing Standard	Indoor / Outdoor Facilities	Site Installation Standard	Nuclear Safety	Personal Safety	Tokamak Complex	Test
HIGH VOLTAGE							
	IEC 60071-2 IEC 60265-2 IEC 62271-1 IEC 62271-102	IEC 60068-1	IEC 60265-2 IEC 61140 IEC 61936 IEC 62271-1 IEC 62271-102 NFC 13000 HD 637 S1	IEC 60068-3-3	IEC 60479 IEC 61140 IEC 62271-1 IEC 62271-102		IEC 60060 – 1 IEC 60068-3-3 IEC 60815 IEC 62271-1 IEC 62271-102
LIGHTNING ARRESTER							
	IEC 60071-1 IEC 60071-2 IEC 60071-4 IEC 60071-5 IEC 60099-1 IEC 60099-4 IEC 60099-5 IEC 60672-3		IEC 61140 IEC 61936 IEC 62305-1 / NF C 17-100 NFC 13000 HD 637 S1	IEC 60068-3-3	IEC 60479 IEC 61140		IEC 60060 – 1 IEC 60068-3-3 IEC 60071-1 IEC 60071-4 IEC 60099-1 IEC 60099-3 IEC 60099-4 IEC 60099-5 IEC 60507 IEC 60815
LINE AND BUSBARS CURRENT TRANSFORMER							
	IEC 60071-2 IEC 60044-1 IEC 60044-6 IEC 60137 IEC 62271-1	IEC 60068-1	IEC 61140 IEC 61936 IEC 62271-1 NFC 13000 HD 637 S1	IEC 60068-3-3	IEC 60479 IEC 61140 IEC 62271-1		IEC 60044-1 IEC 60044-6 IEC 60060 – 1 IEC 60060-2 IEC 60068-3-3 IEC 60137 IEC 60695-2 IEC 60815 IEC 62271-1

SSEN EQUIPMENT	Manufacturing Standard	Indoor / Outdoor Facilities	Site Installation Standard	Nuclear Safety	Personal Safety	Tokamak Complex	Test
HIGH VOLTAGE							
VOLTAGE TRANSFORMER							
	IEC 60044-2 IEC 60071-2 IEC 60137 IEC 62271-1	IEC 60068-1	IEC 61140 IEC 61936 IEC 62271-1 NFC 13000 HD 637 S1	IEC 60068-3-3	IEC 60479 IEC 61140 IEC 62271-1		IEC 60060 – 1 IEC 60060-2 IEC 60068-3-3 IEC 60137 IEC 60695-2 IEC 60815 IEC 62271-1
EARTH SWITCH							
	IEC 60071-2 IEC 62271-1 IEC 62271-102	IEC 60068-1	IEC 61140 IEC 61936 IEC 62271-1 IEC 62271-102 NFC 13000 HD 637 S1	IEC 60068-3-3	IEC 60479 IEC 61140 IEC 62271-102		IEC 60060 – 1 IEC 60060-2 IEC 60068-3-3 IEC 60815 IEC 62271-1 IEC 62271-102
MAIN STEP-DOWN TRANSFORMERS							
STEP-DOWN TRANSFORMER							

SSEN EQUIPMENT	Manufacturing Standard	Indoor / Outdoor Facilities	Site Installation Standard	Nuclear Safety	Personal Safety	Tokamak Complex	Test
HIGH VOLTAGE							
	IEC 60071-2 IEC 60076-1 IEC 60076-2 IEC 60076-3 IEC 60076-4 IEC 60076-5 IEC 60076-11 IEC 60296 IEC 60905 IEC 61000-6-2 IEC 61000-6-4 IEC 61000-5 NF C 52-100 (1990)	IEC 60068-1	IEC 61000-5 IEC 61140 IEC 61936 NFC 13000 HD 637 S1	IEC 60068-3-3	IEC 60479 IEC 61140		IEC 60060 – 1 IEC 60068-2-6 IEC 60068-2-57 IEC 60068-3-3 IEC 60076-1 IEC 60076-2 IEC 60076-3 IEC 60076-4 IEC 60076-5 IEC 60076-11 IEC 61000-6-2 IEC 61000-6-4

4.1.2 MEDIUM VOLTAGE**Table 4.1-2 Standards for MV Electrical Components**

SSEN EQUIPMENT	Manufacturing Standard	Indoor / Outdoor Facilities	Site Installation Standard	Nuclear Safety	Personal Safety	Tokamak Complex	Test
MEDIUM VOLTAGE							
MV 6,6 KV SWITCHGEAR (CLASS 4)							
SWITCHGEAR							
	IEC 60044-1 IEC 60044-2 IEC 60044-8 IEC 60071-2 IEC 60079-7 IEC 60255 IEC 60265-1 IEC 60282-1 IEC 60282-2 IEC 60470 IEC 60529 IEC 61000-5 IEC 61000-6-2 IEC 61000-6-4 IEC 61958 IEC 62271-1 IEC 62271-100 IEC 62271-102 IEC 62271-105 IEC 62271-200 IEC 62271-201 IEC 62271-203 IEC 62271-301	IEC 60068-1	IEC 60265-1 IEC 60470 IEC 61000-5 IEC 61140 IEC 61936 IEC 61958 IEC 62271-1 IEC 62271-100 IEC 62271-102 IEC 62271-105 IEC 62271-200 IEC 62271-201 IEC 62271-203 NFC 13000 NF C13.200 HD 637 S1	IEC 60068-3-3	IEC 60079-7 IEC 60479 IEC 60529 IEC 61140 IEC 61936 IEC 61958 IEC 62271-1 IEC 62271-100 IEC 62271-102 IEC 62271-105 IEC 62271-200 IEC 62271-201 IEC 62271-203	IEC 60754 IEC 61249-2-21	IEC 60060 – 1 IEC 60068-2-2 IEC 60068-2-30 IEC 60068-3-3 IEC 60079-7 IEC 60255 IEC 60265-1 IEC 60282-1 IEC 60282-2 IEC 60470 IEC 60529 IEC 60721-2-1 IEC 60754 IEC 61000-4-2 IEC 61000-6-2 IEC 61000-6-4 IEC 61249-2-21 IEC 61958 IEC 62271-1 IEC 62271-100 IEC 62271-102 IEC 62271-105 IEC 62271-200 IEC 62271-201 IEC 62271-203

SSEN EQUIPMENT	Manufacturing Standard	Indoor / Outdoor Facilities	Site Installation Standard	Nuclear Safety	Personal Safety	Tokamak Complex	Test
MEDIUM VOLTAGE							
MOTOR CONTROL CENTRE							
MCC							
	IEC 60044-1 IEC 60044-2 IEC 60044-8 IEC 60071-2 IEC 60079-7 IEC 60255 IEC 60265-1 IEC 60282-1 IEC 60282-2 IEC 60470 IEC 60529 IEC 61000-5 IEC 61000-6-2 IEC 61000-6-4 IEC 61958 IEC 62271-1 IEC 62271-100 IEC 62271-102 IEC 62271-105 IEC 62271-200 IEC 62271-201 IEC 62271-203 IEC 62271-301	IEC 60068-1	IEC 60265-1 IEC 60470 IEC 61000-5 IEC 61140 IEC 61936 IEC 61958 IEC 62271-1 IEC 62271-100 IEC 62271-102 IEC 62271-105 IEC 62271-200 IEC 62271-201 IEC 62271-203 NFC 13000 NF C13.200 HD 637 S1	IEC 60068-3-3	IEC 60079-7 IEC 60479 IEC 60529 IEC 61140 IEC 61936 IEC 61958 IEC 62271-1 IEC 62271-100 IEC 62271-102 IEC 62271-105 IEC 62271-200 IEC 62271-201 IEC 62271-203	IEC 60754 IEC 61249-2-21	IEC 60060 – 1 IEC 60068-2-2 IEC 60068-2-30 IEC 60068-3-3 IEC 60079-7 IEC 60255 IEC 60265-1 IEC 60282-1 IEC 60282-2 IEC 60470 IEC 60529 IEC 60721-2-1 IEC 60754 IEC 61000-4-2 IEC 61000-6-2 IEC 61000-6-4 IEC 61249-2-21 IEC 61958 IEC 62271-1 IEC 62271-100 IEC 62271-102 IEC 62271-105 IEC 62271-200 IEC 62271-201 IEC 62271-203

SSEN EQUIPMENT	Manufacturing Standard	Indoor / Outdoor Facilities	Site Installation Standard	Nuclear Safety	Personal Safety	Tokamak Complex	Test
MEDIUM VOLTAGE							
CIRCUIT BREAKER							
	IEC 60071-2 IEC 60079-7 IEC 60265-1 IEC 61000-5 IEC 61000-6-2 IEC 61000-6-4 IEC 62271-1 IEC 62271-100 IEC 62271-102 IEC 62271-105 IEC 62271-200	IEC 60068-1	IEC 60265-1 IEC 61000-5 IEC 61140 IEC 61936 IEC 62271-1 IEC 62271-100 IEC 62271-102 IEC 62271-105 IEC 62271-200 NFC 13000 NF C13.200 HD 637 S1	IEC 60068-3-3	IEC 60079-7 IEC 60479 IEC 61140 IEC 61958 IEC 62271-1 IEC 62271-100 IEC 62271-102 IEC 62271-105 IEC 62271-200 EN 50019	IEC 60754 IEC 61249-2-21	IEC 60060 – 1 IEC 60079-7 IEC 60068-2-2 IEC 60068-2-30 IEC 60068-3-3 IEC 60721-2-1 IEC 60754 IEC 61000-6-2 IEC 61000-6-4 IEC 61249-2-21
Income circuit breaker Coupling circuit breaker Outlets circuit breaker							
COUPLER DISCONNECTOR							
	IEC 60071-2 IEC 60079-7 IEC 60265-1 IEC 61000-5 IEC 61000-6-2 IEC 61000-6-4 IEC 62271-1 IEC 62271-102	IEC 60068-1	IEC 60265-1 IEC 61000-5 IEC 61140 IEC 61936 IEC 62271-1 IEC 62271-102 NFC 13000 NF C13.200 HD 637 S1	IEC 60068-3-3	IEC 60079-7 IEC 60479 IEC 61140 IEC 62271-1 IEC 62271-102	IEC 60754 IEC 61249-2-21	IEC 60060 – 1 IEC 60068-3-3 IEC 60079-7 IEC 60265-1 IEC 60754 IEC 61000-6-2 IEC 61000-6-4 IEC 61249-2-21 IEC 62271-1 IEC 62271-102

SSEN EQUIPMENT	Manufacturing Standard	Indoor / Outdoor Facilities	Site Installation Standard	Nuclear Safety	Personal Safety	Tokamak Complex	Test
MEDIUM VOLTAGE							
FUSES							
	IEC 60071-2 IEC 60079-7 IEC 60282-1 IEC 60282-2 IEC 60787 IEC 61000-5 IEC 61000-6-2 IEC 61000-6-4 IEC 62271-1 IEC 62271-105	IEC 60068-1	IEC 61000-5 IEC 61140 IEC 61936 IEC 62271-1 IEC 62271-105 NFC 13000 NF C13.200 HD 637 S1	IEC 60068-3-3	IEC 60079-7 IEC 60479 IEC 61140 IEC 62271-1 IEC 62271-105	IEC 60754 IEC 61249-2-21	IEC 60060 – 1 IEC 60068-3-3 IEC 60079-7 IEC 60282-1 IEC 60282-2 IEC 60754 IEC 61000-6-2 IEC 61000-6-4 IEC 61249-2-21 IEC 62271-1 IEC 62271-105
INSTRUMENTATION TRANSFORMERS							
	IEC 60044-1 IEC 60044-2 IEC 60044-6 IEC 60071-2 IEC 60079-7 IEC 61000-5 IEC 61000-6-2 IEC 61000-6-4 IEC 62271-1	IEC 60068-1	IEC 61000-5 IEC 61140 IEC 61936 IEC 62271-1 NFC 13000 NF C13.200 HD 637 S1	IEC 60068-3-3	IEC 60079-7 IEC 60479 IEC 61140 IEC 62271-1	IEC 60754 IEC 61249-2-21	IEC 60044-1 IEC 60044-2 IEC 60060 – 1 IEC 60068-3-3 IEC 60079-7 IEC 60216 IEC 60754 IEC 61000-6-2 IEC 61000-6-4 IEC 61249-2-21 IEC 62271-1
Current transformers (windows type) Voltage transformers zero sequential toroidal transformers							

SSEN EQUIPMENT	Manufacturing Standard	Indoor / Outdoor Facilities	Site Installation Standard	Nuclear Safety	Personal Safety	Tokamak Complex	Test
MEDIUM VOLTAGE							
RELAYS							
	IEC 60071-2 IEC 60255 IEC 61000-5 IEC 61000-6-2 IEC 61000-6-4	IEC 60068-1	IEC 61000-5 IEC 61140 IEC 61936 NFC 13000 NF C13.200 HD 637 S1	IEC 60068-3-3	IEC 60079-7 IEC 60479 IEC 61140	IEC 60754 IEC 61249-2-21	IEC 60060 – 1 IEC 60068-2 IEC 60068-3-3 IEC 60255-5 IEC 60255-11 IEC 60754 IEC 61000-4-2 IEC 61000-4-3 IEC 61000-4-4 IEC 61000-4-5 IEC 61000-4-6 IEC 61000-4-8 IEC 61000-4-10 IEC 61000-4-12 IEC 61000-6-2 IEC 61000-6-4 IEC 61249-2-21 EN 55022

SSEN EQUIPMENT	Manufacturing Standard	Indoor / Outdoor Facilities	Site Installation Standard	Nuclear Safety	Personal Safety	Tokamak Complex	Test
MEDIUM VOLTAGE							
MEDIUM VOLTAGE POWER CABLES							
	IEC 60038 IEC 60055-2 IEC 60071-2 IEC 60183 IEC 60228 IEC 60287 IEC 60304 IEC 60502 IEC 60840 (ABOVE 36KV) IEC 60949 IEC 61000-5 IEC 61000-6-2 IEC 61000-6-4 NF C 32070 NF C 32323 HD 308 HD 620S1 HD 632 S1 (above 36 kV) HD 632.16 (above 36 kV)	IEC 60068-1	IEC 61000-5 IEC 61140 IEC 61936 NFC 13000 NF C13.200 HD 637 S1	IEC 60068-3-3 IEC 60780 IEC 60980	IEC 60079-7 IEC 60446 IEC 60479 IEC 61140	IEC 60754 IEC 61249-2-21 EN 50267-2-1	IEC 60055-1 IEC 60332-1 IEC 60332-2 IEC 60332-3-24 IEC 60502 IEC 60754 IEC 60811 IEC 60840 (ABOVE 30KV) IEC 61034 IEC 61000-6-2 IEC 61000-6-4 EN 50266-2-4 EN 50267-2-1 EN 50267-2-3 NFC 20454 NF C 32070
MV SWITCHGEAR (CLASS 3) SR (*)							
(*) Comply with the standards shown above but it has to be into account safety relevant condition				IEC 60068-3-3 IEC 60780 IEC 60980		IEC 60754 IEC 61249-2-21	

SSEN EQUIPMENT	Manufacturing Standard	Indoor / Outdoor Facilities	Site Installation Standard	Nuclear Safety	Personal Safety	Tokamak Complex	Test
MEDIUM VOLTAGE							
EMERGENCY POWER SUPPLY							
DIESEL GENERATOR WITH AUXILIARIES							
	IEC 60034 IEC 60071-2 IEC 60529 IEC 60950 IEC 61131-3 IEC 62305-3 IEC 61000-5 IEC 61000-6-2 IEC 61000-6-4	IEC 60068-1	IEC 60950 IEC 61000-5 IEC 61140 IEC 61936 NFC 13000 NF C13.200 HD 637 S1	IEC 60068-3-3 IEC 60780 IEC 60980	IEC 60079-7 IEC 60479 IEC 61140		IEC 60060 – 1 IEC 60529 IEC 61000-6-2 IEC 61000-6-4
Main motor							
Generator							

SSEN EQUIPMENT	Manufacturing Standard	Indoor / Outdoor Facilities	Site Installation Standard	Nuclear Safety	Personal Safety	Tokamak Complex	Test
MEDIUM VOLTAGE							
Control Panels							
MOTORS							

SSEN EQUIPMENT	Manufacturing Standard	Indoor / Outdoor Facilities	Site Installation Standard	Nuclear Safety	Personal Safety	Tokamak Complex	Test
MEDIUM VOLTAGE							
	IEC 60034-1 IEC 60034-2 IEC 60034-5 IEC 60034-6 IEC 60034-7 IEC 60034-8 IEC 60034-9 IEC 60034-11 IEC 60034-12 IEC 60034-14 IEC 60071-2 IEC 60072-1 IEC 60072-2 IEC 60072-3 IEC 60079-0 IEC 60079-1 IEC 60079-2 IEC 60079-7 IEC 60079-14 IEC 60079-15 IEC 60079-19 IEC 60204-11 IEC 60071-2 IEC 61000-5 IEC 61000-6-2 IEC 61000-6-4 IEC 61241-0 IEC 61241-1 IEC 61241-11 IEC 61241-17	IEC 60068-1	IEC 60034-7 IEC 60079-14 IEC 60204-11 IEC 61000-5 IEC 61140 IEC 61241-14 IEC 61936 NFC 13000 NF C13.200 HD 637 S1	IEC 60068-3-3 IEC 60780 (SR) IEC 60980 (SR)	IEC 60034-5 IEC 60204-11 IEC 60479 IEC 60529 IEC 61140	IEC 60754 IEC 61249-2-21	IEC 60034-1 IEC 60034-2 IEC 60034-5 IEC 60034-9 IEC 60034-11 IEC 60034-12 IEC 60060 – 1 IEC 60071-2 IEC 60079-0 IEC 60079-1 IEC 60079-2 IEC 60079-7 IEC 60079-14 IEC 60079-15 IEC 60079-19 IEC 60204-11 IEC 60754 IEC 61000-6-2 IEC 61000-6-4 IEC 61241-0 IEC 61241-1 IEC 61241-11 IEC 61241-17 IEC 61249-2-21
SPEED DRIVES							

SSEN EQUIPMENT	Manufacturing Standard	Indoor / Outdoor Facilities	Site Installation Standard	Nuclear Safety	Personal Safety	Tokamak Complex	Test
MEDIUM VOLTAGE							
	IEC 60071-2 IEC 60079-0 IEC 60079-1 IEC 61000-2-4 IEC 61000-5 IEC 61000-6-2 IEC 61000-6-4 IEC 61241-0 IEC 61241-1 IEC 61800-3 IEC 61800-4 EN 50178	IEC 60068-1	IEC 60204-1 IEC 61000-5 IEC 61140 IEC 61800-1 IEC 61800-2 IEC 61800-5 IEC 61936 NFC 13000 NF C13.200 HD 637 S1 EN 50178	IEC 60068-3-3 IEC 60780 (SR) IEC 60980 (SR)	IEC 60204-1 IEC 60479 IEC 61140	IEC 60754 IEC 61249-2-21	IEC 60060-1 IEC 60068-3-3 IEC 60079-0 IEC 60079-1 IEC 60754 IEC 61000-2-4 IEC 61000-6-2 IEC 61000-6-4 IEC 61241-0 IEC 61241-1 IEC 61249-2-21 IEC 61800-3 IEC 61800-4

4.1.3 LOW VOLTAGE**Table 4.1-3 Standards for LV Electrical Components**

SSEN EQUIPMENT	Manufacturing Standard	Indoor / Outdoor Facilities	Site Installation Standard	Nuclear Safety	Personal Safety	Tokamak Complex	Test
LOW VOLTAGE							
MV / LV DISTRIBUTION TRANSFORMERS							
	IEC 60076-1 IEC 60076-2 IEC 60076-3 IEC 60076-4 IEC 60076-5 IEC 60076-10 IEC 60076-11 IEC 60296 IEC 60664-1 IEC 61000-5 IEC 61000-6-2 IEC 61000-6-4 HD 538-2 S1 NF C 52-112 / NF EN 50464	IEC 60068-1 IEC 60364	IEC 60076-7 IEC 60364 IEC 60905 IEC 61000-5 IEC 61140 NF C15-100	IEC 60068-3-3 IEC 60780 (SR) IEC 60980 (SR)	IEC 60364-4 IEC 60479 IEC 61140 NF C15-100	IEC 60754 IEC 61249-2-21	IEC 60068-3-3 IEC 60076-1 IEC 60076-2 IEC 60076-3 IEC 60076-4 IEC 60076-5 IEC 60076-5 IEC 60076-11 IEC 60664-1 IEC 60754 IEC 61000-6-2 IEC 61000-6-4 IEC 61249-2-21
DRY TRANSFORMER							
OIL TRANSFORMER							

SSEN EQUIPMENT	Manufacturing Standard	Indoor / Outdoor Facilities	Site Installation Standard	Nuclear Safety	Personal Safety	Tokamak Complex	Test
LOW VOLTAGE							
LOCAL INSTRUMENTATION CONTROL, PROTECTION SYSTEM							
LOAD DISTRIBUTION CENTRE (CLASS 4 & 3) IP							
	IEC 60269 IEC 60439-1 IEC 60529 IEC 60664-1 IEC 60715 IEC 60947-1 IEC 60947-2 IEC 60947-3 IEC 60947-4 IEC 60947-5 IEC 60947-6 IEC 60947-7 IEC 61000-5 IEC 61000-6-2 IEC 61000-6-4 IEC 62208/EN 50298 EN 50 102 NF C 20-010/IEC 60529/EN 50 102 NF C 20-015/IEC 62262 NF C 20-030/IEC 61140 NF C 20-040/IEC 60664-4	IEC 60068-1 IEC 60364	IEC 60364 IEC 60439-1 IEC 60947-1 IEC 60947-2 IEC 60947-3 IEC 60947-4 IEC 60947-5 IEC 60947-6 IEC 60947-7 IEC 61000-5 IEC 61140 NF C15-100	IEC 60068-3-3	IEC 60364-4 IEC 60439-1 IEC 60479 IEC 60529 IEC 61140 NF C15-100	IEC 60754 IEC 61249-2-21	IEC 60068-3-3 IEC 60439-1 IEC 60529 IEC 60664-1 IEC 60754 IEC 60947 IEC 61000 IEC 61249-2-21 IEC 61641 IEC 62262 NF C 63-421/IEC 60439-1 NF C 20-010/IEC 60529 NF C 20-015/IEC 62262 NF C 20-030/IEC 61140 NF C 20-040/IEC 60664-4

SSEN EQUIPMENT	Manufacturing Standard	Indoor / Outdoor Facilities	Site Installation Standard	Nuclear Safety	Personal Safety	Tokamak Complex	Test
LOW VOLTAGE							
CIRCUIT BREAKER							
	IEC 60664-1 IEC 60947-1 IEC 60947-2 IEC 61000-5 IEC 61000-6-2 IEC 61000-6-4	IEC 60068-1 IEC 60364	IEC 60364 IEC 60947-1 IEC 60947-2 IEC 61000-5 IEC 61140 NF C15-100	IEC 60068-3-3	IEC 60364-4 IEC 60479 IEC 61140 NF C15-100	IEC 60754 IEC 61249-2-21	IEC 60068-3-3 IEC 60439-1 IEC 60664-1 IEC 60947-1 IEC 60947-2 IEC 61000-4-2 IEC 61000-4-4 IEC 61000-4-8 IEC 61000-4-9 IEC 61000-4-10 IEC 61000-4-13 IEC 61000-6-2 IEC 61000-6-4
Income and coupling automatic circuit breaker (double-ended type)							
Circuit Breaker for outgoing circuits Thermal magnetic breaker							

SSEN EQUIPMENT	Manufacturing Standard	Indoor / Outdoor Facilities	Site Installation Standard	Nuclear Safety	Personal Safety	Tokamak Complex	Test
LOW VOLTAGE							
PROTECTION RELAYS							
	IEC 60255 IEC 60664-1 IEC 60755 IEC 60947-1 IEC 60947-5-1 IEC 61000-5 IEC 61000-6-2 IEC 61000-6-4	IEC 60068-1 IEC 60364	IEC 60364 IEC 60755 IEC 60947-1 IEC 60947-5-1 IEC 60755 IEC 61000-5 IEC 61140 NF C15-100	IEC 60068-3-3	IEC 60364-4 IEC 60479 IEC 60755 IEC 61140 NF C15-100	IEC 60754-1 IEC 61249-2-21	IEC 60060 – 1 IEC 60068-2 IEC 60068-3-3 IEC 60255-5 IEC 60255-11 IEC 60529 IEC 60664-1 IEC 60754-1 IEC 60755 IEC 61000-4-2 IEC 61000-4-3 IEC 61000-4-4 IEC 61000-4-5 IEC 61000-4-6 IEC 61000-4-8 IEC 61000-4-10 IEC 61000-4-12 IEC 61000-6-2 IEC 61000-6-4 IEC 61249-2-21 EN 55022
Motor Electronic protection relay							
Undervoltage (ANSI) relay							
DC undervoltage relay (ANSI 80)							
Differential Relay							
Isolation relays							

SSEN EQUIPMENT	Manufacturing Standard	Indoor / Outdoor Facilities	Site Installation Standard	Nuclear Safety	Personal Safety	Tokamak Complex	Test
LOW VOLTAGE							
INSTRUMENT TRANSFORMERS							
	IEC 60044-1 IEC 60044-2 IEC 60664-1 IEC 61000-5 NF C 42502	IEC 60068-1 IEC 60364	IEC 60364 IEC 61000-5 IEC 61140 NF C15-100		IEC 60364-4 IEC 60479 IEC 61140 NF C15-100	IEC 60754 IEC 61249-2-21	IEC 60044-1 IEC 60044-2 IEC 60664-1 IEC 60754 IEC 61249-2-21 NF C 42502
Potential transformers							
Current transformers							
METERING UNIT (Comprise all components)							
	IEC 60051 IEC 60359 IEC 60529 IEC 60664-1 IEC 61000-5 IEC 61000-6-2 IEC 61000-6-4 IEC 62053	IEC 60068-1 IEC 60364	IEC 60364 IEC 61000-5 IEC 61140 NF C15-100		IEC 60364-4 IEC 60479 IEC 60529 IEC 61140 IEC 61010-1 NF C15-100	IEC 60754 IEC 61249-2-21	IEC 60529 IEC 60664-1 IEC 60754 IEC 61000-4-2 IEC 61000-4-3 IEC 61000-4-4 IEC 61000-4-5 IEC 61000-4-6 IEC 61000-4-8 IEC 61000-4-11 IEC 61000-6-2 IEC 61000-6-4 IEC 61010-1 IEC 61249-2-21 EN 55011
Voltmeter Ammeter Communication bus communication protocol							

SSEN EQUIPMENT	Manufacturing Standard	Indoor / Outdoor Facilities	Site Installation Standard	Nuclear Safety	Personal Safety	Tokamak Complex	Test
LOW VOLTAGE							
LOAD DISTRIBUTION CENTRE (CLASS 3) SR (*)							
(*) Comply with the standards shown above but it has to be into account safety relevant condition				IEC 60068-3-3 IEC 60780 IEC 60980		IEC 60754 IEC 61249-2-21	

SSEN EQUIPMENT	Manufacturing Standard	Indoor / Outdoor Facilities	Site Installation Standard	Nuclear Safety	Personal Safety	Tokamak Complex	Test
LOW VOLTAGE							
MOTORS							
	IEC 60034-1 IEC 60034-2 IEC 60034-5 IEC 60034-6 IEC 60034-7 IEC 60034-8 IEC 60034-9 IEC 60034-11 IEC 60034-12 IEC 60034-14 IEC 60072-1 IEC 60072-2 IEC 60072-3 IEC 60079-0 IEC 60079-1 IEC 60079-2 IEC 60079-7 IEC 60079-14 IEC 60079-15 IEC 60079-19 IEC 60664-1 IEC 61000-5 IEC 61000-6-2 IEC 61000-6-4 IEC 61241-0 IEC 61241-1 IEC 61241-11 IEC 61241-17	IEC 60068-1 IEC 60364	IEC 60034-7 IEC 60079-14 IEC 60204-1 IEC 60364 IEC 61000-5 IEC 61241-14 IEC 61140 NF C15-100	IEC 60068-3-3 IEC 60780 (SR) IEC 60980 (SR)	IEC 60034-5 IEC 60204-1 IEC 60364-4 IEC 60034-5 IEC 60479 IEC 61140 NF C15-100	IEC 60754 IEC 61249-2-21	IEC 60034-1 IEC 60034-2 IEC 60034-5 IEC 60034-9 IEC 60034-11 IEC 60034-12 IEC 60071-2 IEC 60079-0 IEC 60079-1 IEC 60079-2 IEC 60079-7 IEC 60079-14 IEC 60079-15 IEC 60079-19 IEC 60204-11 IEC 60664-1 IEC 60754 IEC 61000-6-2 IEC 61000-6-4 IEC 61241-0 IEC 61241-1 IEC 61241-11 IEC 61241-17 IEC 61249-2-21

SSEN EQUIPMENT	Manufacturing Standard	Indoor / Outdoor Facilities	Site Installation Standard	Nuclear Safety	Personal Safety	Tokamak Complex	Test
LOW VOLTAGE							
SPEED DRIVES							
	IEC 60079-0 IEC 60079-1 IEC 60664-1 IEC 61000-5 IEC 61000-6-2 IEC 61000-6-4 IEC 61800-1 IEC 61800-2 IEC 61800-3 IEC 61800-5 IEC 61241-0 IEC 61241-1 EN 50178	IEC 60068-1 IEC 60364	IEC 60204-1 IEC 60364 IEC 61000-5 IEC 61140 IEC 61800-1 IEC 61800-2 IEC 61800-5 EN 50178 NF C15-100	IEC 60068-3-3 IEC 60780 (SR) IEC 60980 (SR)	IEC 60204-1 IEC 60364-4 IEC 60479 IEC 61140 NF C15-100	IEC 60754 IEC 61249-2-21	IEC 60079-0 IEC 60079-1 IEC 60664-1 IEC 60754 IEC 61000-2-4 IEC 61000-6-2 IEC 61000-6-4 IEC 61241-0 IEC 61241-1 IEC 61249-2-21 IEC 61800-1 IEC 61800-2 IEC 61800-3 IEC 61800-5

SSEN EQUIPMENT	Manufacturing Standard	Indoor / Outdoor Facilities	Site Installation Standard	Nuclear Safety	Personal Safety	Tokamak Complex	Test
LOW VOLTAGE							
LOW VOLTAGE MOTOR CONTROL CENTRE (CLASS 4 & 3) (as an Unit)							
	IEC 60269 IEC 60439 IEC 60529 IEC 60664-1 IEC 60715 IEC 60947-1 IEC 60947-2 IEC 60947-3 IEC 60947-4 IEC 60947-5 IEC 60947-6 IEC 60947-7 IEC 61000-5 IEC 61000-6-2 IEC 61000-6-4 EN 50102	IEC 60068-1 IEC 60364	IEC 60269-2 IEC 60269-3 IEC 60364 IEC 60439 IEC 61000-5 IEC 61140 NF C15-100	IEC 60068-3-3	IEC 60269-2 IEC 60269-3 IEC 60364-4 IEC 60479 IEC 60529 IEC 61140 NF C15-100	IEC 60754 IEC 61249-2-21	IEC 60068-3-3 IEC 60269 IEC 60439-1 IEC 60664-1 IEC 60754 IEC 61000-6-2 IEC 61000-6-4 IEC 61641 IEC 61249-2-21 IEC 61641 IEC 61249-2-21

SSEN EQUIPMENT	Manufacturing Standard	Indoor / Outdoor Facilities	Site Installation Standard	Nuclear Safety	Personal Safety	Tokamak Complex	Test
LOW VOLTAGE							
EMERGENCY POWER SUPPLY							
DIRECT CURRENT SYSTEM (class I)							
	IEC 60038 IEC 60146-2 IEC 60664-1 IEC 60896-11 IEC 60896-21 IEC 60947-1 IEC 60947-2 IEC 60947-3 IEC 61000-5 IEC 61000-6-2 IEC 61000-6-4 IEC 61056-1 IEC 61056-2 IEC 61660-1 IEC 62040-3 EN 55022	IEC 60068-1 IEC 60364	IEC 60364 IEC 60947-2 IEC 60947-3 IEC 61000-5 IEC 61140 NF C15-100	IEC 60068-3-3 IEC 60780 IEC 60980	IEC 60364-4 IEC 60479 IEC 61140 NF C15-100		IEC 60254-1 IEC 60254-2 IEC 60664-1 IEC 60896-11 IEC 60896-21 IEC 60947-1 IEC 60947-2 IEC 60947-3 IEC 61000-4-2 IEC 61000-4-4 IEC 61000-4-5 IEC 61000-4-8 IEC 61000-4-9 IEC 61000-4-10 IEC 61000-4-13 IEC 61000-4-17 IEC 61000-6-2 IEC 61000-6-4 IEC 62040-2 EN 55022 NF C 58-311
125 Vdc lead-acid accumulator, Stationary battery							

SSEN EQUIPMENT	Manufacturing Standard	Indoor / Outdoor Facilities	Site Installation Standard	Nuclear Safety	Personal Safety	Tokamak Complex	Test
LOW VOLTAGE							
	IEC 60038 IEC 60664-1 IEC 60896-11 IEC 60896-21 IEC 61000-5 IEC 61000-6-2 IEC 61000-6-4 IEC 61056-1 IEC 61056-2	IEC 60068-1 IEC 60364	IEC 60364 IEC 61000-5 IEC 61140 NF C15-100	IEC 60068-3-3 IEC 60780 IEC 60980	IEC 60364-4 IEC 60479 IEC 61140 NF C15-100		IEC 60254-1 IEC 60254-2 IEC 60664-1 IEC 60896-11 IEC 60896-21 IEC 61000-4-17 IEC 61000-6-2 IEC 61000-6-4 NF C 58-311
400 Vac/250 Vdc charger							
	IEC 60146-2 IEC 60664-1 IEC 61000-5 IEC 61000-6-2 IEC 61000-6-4 IEC 62040-3 EN 55022	IEC 60068-1 IEC 60364	IEC 60364 IEC 61000-5 IEC 61140 NF C15-100	IEC 60068-3-3 IEC 60780 IEC 60980	IEC 60364-4 IEC 60479 IEC 61140 NF C15-100		IEC 60664-1 IEC 61000-4-4 IEC 61000-4-5 IEC 61000-4-17 IEC 61000-6-4 IEC 62040-2 EN 55022 NF C 58-311
Dc circuit breakers							
	IEC 60664-1 IEC 60947-1 IEC 60947-2 IEC 60947-3 IEC 61660-1 IEC 61000-5 IEC 61000-6-2 IEC 61000-6-4	IEC 60068-1 IEC 60364	IEC 60364 IEC 60947-1 IEC 60947-2 IEC 60947-3 IEC 61000-5 IEC 61140	IEC 60068-3-3 IEC 60780 IEC 60980	IEC 60364-4 IEC 60479 IEC 61140 NF C15-100		IEC 60664-1 IEC 60947-1 IEC 60947-2 IEC 60947-3 IEC 61000-4-2 IEC 61000-4-4 IEC 61000-4-8 IEC 61000-4-9 IEC 61000-4-10 IEC 61000-4-13 IEC 61000-6-2 IEC 61000-6-4

SSEN EQUIPMENT	Manufacturing Standard	Indoor / Outdoor Facilities	Site Installation Standard	Nuclear Safety	Personal Safety	Tokamak Complex	Test
LOW VOLTAGE							
REGULATED UNINTERRUPTIBLE SYSTEM (UPS)							
	IEC 60664-1 IEC 60950-1 IEC 61000-5 IEC 61000-6-2 IEC 61000-6-4 IEC 62040-1-1 IEC 62040-1-2 IEC 62040-2 IEC 62040-3 IEC 60950-1 EN 55022	IEC 60068-1 IEC 60364	IEC 60364-1 IEC 60364-4 IEC 61000-5 IEC 61140 NF C15-100	IEC 60068-3-3 IEC 60780 IEC 60980	IEC 60364-4 IEC 60479 IEC 61140 IEC 62040-1-1 IEC 62040-1-2 NF C15-100		IEC 60664-1 IEC 61000-4-17 IEC 61000-6-2 IEC 61000-6-4 IEC 62040-2 IEC 62040-3 EN 55022
Static inverter							
	IEC 60146-2 IEC 60664-1 IEC 60950-1 IEC 61000-5 IEC 62040-1 IEC 62040-3 EN 55022	IEC 60364	IEC 60364-1 IEC 60364-4 IEC 61000-5 IEC 61140 NF C15-100	IEC 60068-3-3 IEC 60980 IEC 60780	IEC 60364-4 IEC 60479 IEC 61140 IEC 62040-1-1 IEC 62040-1-2 NF C15-100		IEC 60664-1 IEC 61000-6-2 IEC 61000-6-4
Static transfer switch							

SSEN EQUIPMENT	Manufacturing Standard	Indoor / Outdoor Facilities	Site Installation Standard	Nuclear Safety	Personal Safety	Tokamak Complex	Test
LOW VOLTAGE							
	IEC 60146-1-1 IEC 60146-1-3 IEC 60146-2 IEC 60439-1 IEC 60439-2 IEC 60439-3 IEC 60664-1 IEC 61000-5 IEC 61000-6-2 IEC 61000-6-4 IEC 62310-1 IEC 62310-2 EN50178	IEC 60068-1 IEC 60364	IEC 60364 IEC 60439-1 IEC 60439-2 IEC 60439-3 IEC 61000-5 IEC 61140 NF C15-100	IEC 60068-3-3 IEC 60780 IEC 60980	IEC 60364-4 IEC 60439-1 IEC 60479 IEC 60529 IEC 61140 IEC 62310-1 NF C15-100		IEC 60439-1 IEC 60664-1 IEC 61000-6-2 IEC 61000-6-4
Batteries (open vs. closed)							
	IEC 60896-11 IEC 60896-21 IEC 61056-1 IEC 61056-2 IEC 61000-5 IEC 61000-6-2 IEC 61000-6-4	IEC 60068-1 IEC 60364	IEC 60364 IEC 61000-5 IEC 61140 NF C15-100	IEC 60068-3-3 IEC 60780 IEC 60980	IEC 60364-4 IEC 60479 IEC 61140 NF C15-100		IEC 60664-1 IEC 60695-11-10 IEC 60695-11-20 IEC 61000-4-17 IEC 61000-6-2 IEC 61000-6-4

SSEN EQUIPMENT	Manufacturing Standard	Indoor / Outdoor Facilities	Site Installation Standard	Nuclear Safety	Personal Safety	Tokamak Complex	Test
LOW VOLTAGE							
LV POWER CABLES AND CONTROL CABLES							

SSEN EQUIPMENT	Manufacturing Standard	Indoor / Outdoor Facilities	Site Installation Standard	Nuclear Safety	Personal Safety	Tokamak Complex	Test
LOW VOLTAGE							
	IEC 60227 IEC 60228 IEC 60245 IEC 60287-1-1 IEC 60304 IEC 60664-1 IEC 61000-5 IEC 61000-6-2 IEC 61000-6-4 IEC 61210 IEC 62440 HD 22.9.S3 HD 21.5 S 3 HD 21.3 S 3 HD 22.4S4 HD 22.6S2 HD 308 HD 361 HD 603 S1 NF C 30202 NF C 32070 NFC 32102.13 NF C 32323	IEC 60068-1 IEC 60364 IEC 60364-5-52 IEC 60364-4-43	IEC 60364 IEC 61000-5 IEC 61140 NF C15-100	IEC 60068-3-3 IEC 60780 (SR) IEC 60980 (SR)	IEC 60364-4 IEC 60446 IEC 60479 IEC 61140 NF C15-100	IEC 60754-1 NF C 32070 EN 50267-2-1	IEC 60055 IEC 60093 IEC 60227 IEC 60243 IEC 60245 IEC 60250 IEC 60331 IEC 60332-1 IEC 60332-2 IEC 60332-3 IEC 60664-1 IEC 60684-2 IEC 60754-1 IEC 60754-2 IEC 60811 IEC 61000-6-2 IEC 61000-6-4 IEC 61034-1 IEC 61034-2 IEC 61210 EN 50266-1 EN 50266-2-2 EN 50266-2-3 EN 50266-2-4 EN 50266-2-5 EN 50267-1 EN 50267-2-1 EN 50267-2-2 NF C 20454 NF C 32070 NF C 32076
CABLE TRAYS							

SSEN EQUIPMENT	Manufacturing Standard	Indoor / Outdoor Facilities	Site Installation Standard	Nuclear Safety	Personal Safety	Tokamak Complex	Test
LOW VOLTAGE							
	IEC 61537 NF P 92507 EN 10327 EN 12329 EN 12330 EN 10088-2	IEC 60068-1 IEC 60364 EN 10327 EN 12329 EN 12330 EN 10088-2	IEC 60364	IEC 60068-3-3 IEC 60780 (SR) IEC 60980 (SR)		IEC 60754-1 NF C 32070	EN 10327 EN 10088-2
LIGHTING SYSTEM							
LIGHTING							
Metal halide lamps							
	IEC 60664-1 IEC 60927 IEC 61000-5 IEC 61000-6-2 IEC 61000-6-4 IEC 61167 IEC 61347-1 IEC 61347-2-1 IEC 61547 EN 55015	IEC 60068-1 IEC 60364 IEC 60364-7-714	IEC 60364 IEC 61000-5 IEC 61140 NF C15-100	IEC 60068-3-3	IEC 60364-4 IEC 60479 IEC 61347-1 IEC 61347-2-1 IEC 61140 IEC 61347-1 NF C15-100	IEC 60754 IEC 61249-2-21	IEC 60068-3-3 IEC 60664-1 IEC 60754 IEC 61000-6-2 IEC 61000-6-4 IEC 61167 IEC 61249-2-21 IEC 61547 EN 55015
High-pressure sodium vapour lamps							
	IEC 60662 IEC 60664-1 IEC 60923 IEC 61000-5 IEC 61000-6-2 IEC 61000-6-4 IEC 61347-2-9 IEC 61547 EN 55015	IEC 60068-1 IEC 60364 IEC 60364-7-714	IEC 60364 IEC 61000-5 IEC 61140 NF C15-100	IEC 60068-3-3	IEC 60364-4 IEC 60479 IEC 61140 NF C15-100	IEC 60754 IEC 61249-2-21	IEC 60664-1 IEC 60754 IEC 61000-6-2 IEC 61000-6-4 IEC 61249-2-21 IEC 61547 EN 55015
Fluorescent lamps							

SSEN EQUIPMENT	Manufacturing Standard	Indoor / Outdoor Facilities	Site Installation Standard	Nuclear Safety	Personal Safety	Tokamak Complex	Test
LOW VOLTAGE							
	IEC 60081 IEC 60664-1 IEC 60901 IEC 60929 IEC 61000-5 IEC 61000-6-2 IEC 61000-6-4 IEC 61195 IEC 61347-1 IEC 61347-2-3 IEC 61547 EN 55015	IEC 60068-1 IEC 60364 IEC 60364-7-714	IEC 60364 IEC 61000-5 IEC 61140 NF C15-100	IEC 60068-3-3	IEC 60364-4 IEC 60479 EN 60901 IEC 61140 IEC 61195 IEC 61199 IEC 61347-1 IEC 61347-2-3 NF C15-100	IEC 61249-2-21 IEC 60754	IEC 60664-1 IEC 60754 IEC 61000-6-2 IEC 61000-6-4 IEC 61249-2-21 IEC 61547 EN 55015
High frequency ballast lamps							
	IEC 60081 IEC 60664-1 IEC 60901 IEC 60929 IEC 61000-5 IEC 61000-6-2 IEC 61000-6-4 IEC 61347-1 IEC 61347-2-3 IEC 61547 EN 55015 EN 50294	IEC 60068-1 IEC 60364 IEC 60364-7-714	IEC 60364 IEC 61000-5 IEC 61140 NF C15-100	IEC 60068-3-3	IEC 60364-4 IEC 60479 EN 60901 IEC 61140 IEC 61347-1 IEC 61347-2-3 NF C15-100	IEC 61249-2-21 IEC 60754	IEC 60664-1 IEC 60754 IEC 61000-6-2 IEC 61000-6-4 IEC 61249-2-21 IEC 61547 EN 55015